

## **PORTABLE (POWER OPERATED) TOOLS AND EQUIPMENT**

- ☐ Are grinders, saws and similar equipment provided with appropriate safety guards?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Are power tools used with the correct shield, guard, or attachment, recommended by the manufacturer?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Are portable circular saws equipped with guards above and below the base shoe?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Are circular saw guards checked to assure they are not wedged up, thus leaving the lower portion of the blade unguarded?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Are rotating or moving parts of equipment guarded to prevent physical contact?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Are all cord-connected, electrically operated tools and equipment effectively grounded or of the approved double insulated type?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Are effective guards in place over belts, pulleys, chains, sprockets, on equipment such as concrete mixers, air compressors, etc.?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Are portable fans provided with full guards or screens having openings 1/2 inch or less?

**Action to be Taken**

**Assigned To:**

---

---

## Portable (Power Operated) Tools and Equipment

- ☐ Is hoisting equipment available and used for lifting heavy objects, and are hoist ratings and characteristics appropriate for the task?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Are ground-fault circuit interrupters provided on all temporary electrical 15 and 20-ampere circuits, used during periods of construction?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Are pneumatic and hydraulic hoses on power-operated tools checked regularly for deterioration or damage?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Are precautions taken when using fuel-powered tools in enclosed spaces?

**Action to be Taken**

**Assigned To:**

---

---